# Programmable transmitter of temperature, relative humidity and other derived humidity values

## T3419

Programmable transmitter of atmospheric pressure, temperature, relative humidity and other derived humidity values

T7311, T7411

# with RS232 / RS485 serial output and external probe

**Instruction Manual** 

### **Instruction Manual**

Device type	Temperature	Humidity	Pressure	Computed value	Output	Galvanic isolated output
T3419	✓	✓	-	✓	RS485	✓
T7311	✓	✓	✓	✓	RS232	-
T7411	✓	✓	✓	✓	RS485	✓

Device is designed for measurement of ambient temperature at °C or °F, relative humidity of air without aggressive ingredients with computing one of the following values: dew point temperature, absolute humidity, specific humidity, mixing ratio and specific enthalpy. Devices T7311 and T7411 support atmospheric pressure measurement at hPa, PSI, inHg, mBar, oz/in², mmHg, inH<sub>2</sub>O and kPa too. It is possible to set pressure correction for altitude (offset). Device setting is provided by user's software, see latter. Device T7311 communicates via link RS232, devices T3419 and T7411 via link RS485. Supported communication protocols are Modbus RTU, protocol compatible with standard Advantech-ADAM, ARION and communication with HWg–Poseidon devices. Devices are preset from manufacturer to Modbus RTU communication protocol. If you would like to use different communication protocol then Modbus RTU, it is necessary preset them through user's software – see latter. Temperature, relative humidity eventually pressure sensors are non-removable device parts, pressure sensor is placed inside the electronic case. Measured and computed values are optionally shown on dual line LCD display. If there are two values displayed at one LCD line, they are periodically switched between both readings with period of 4 seconds. Display can be switched OFF totally too.

Use user's software *Tsensor* for setting of all device parameters (recommended). It is free to download at <a href="www.cometsystem.cz">www.cometsystem.cz</a>. It supports make the adjustment of the device too. This procedure is described at file "*Calibration manual.pdf*" which is installed commonly with the software. Change of some parameters is possible to do without user's software with Windows hyperterminal (change of communication protocol, its parameters, LCD display setting). It is described in file "*Description of communication protocols of Txxxx series*" which is free to download at the same address.

**Transmitter version T**xxxxL with watertight male connector instead of a cable gland (RS232) or glands (RS485) is designed for easy connection/disconnection of communication cable. Male Lumberg connector RSFM4 has protection IP67.

**Models marked T**xxxx**Z** are non-standard versions of the transmitters. Description is not included in this manual.

Please read instruction manual before the first device connection.

## **Device setting from the manufacturer**

If special setting was not required in the order the device is set from the manufacturer to the following parameters:

communication protocol: Modbus RTU

device address: **01H** 

communication speed: 9600Bd, without parity, 2 stop bits

display: switched ON

value displayed at higher line: **temperature** (**temperature** / **pressure**) – by device type

value displayed at lower line: relative humidity only

temperature unit: °C

pressure unit: **hPa** 

preset computed value: dew point temperature correction for altitude: 0 hPa (absolute pressure)

#### **Device installation**

Device is designed for wall mounting. There are two mounting holes at the sides of the case. It is NOT recommended to use the device for long time under condensation conditions. It could be the cause of water steam condensation inside the sensor's cover into water phase. This liquid phase stays inside sensor's cover and can't escape from the cover easily. It can dramatically increase response time to relative humidity change. If water condensation occurs for longer time it can cause sensor damage. Similar effect can occur under water aerosol conditions. Don't connect device while power supply voltage is on. Interconnection terminals for T3419, T7311 and T7411 devices are accessible after unscrewing four screws and removing the lid. Measuring temperature, relative humidity and eventually pressure sensors are non-removable device parts. Lace the cable through a gland at the case wall. Connect the cable to terminals with respecting the signal polarity (see figure). Terminals are self-clamping and can be opened by a suitable screwdriver. For the opening, insert the screwdriver to smaller terminal hole and lever by him. Do not forget to tighten glands and case lid with inserted packing after cables connecting. It is necessary for warranting of protection IP65. Connect complementary female connector for T3419L, T7311L and T7411L transmitters in accordance with the table in Appendix B of this manual.

Devices T7311 are supplied with connection cable equipped with connector for connection to RS232 interface. For devices with RS485 output there is recommended to use shielded twisted copper cable, maximal length 1200m. The cable must be located at indoor rooms. Nominal cable impedance should be  $100~\Omega$ , loop resistance max.  $240~\Omega$ , cable capacity max. 65~pF/m. Outside diameter of the cable for T3419 and T7411 connection must be from 3 to 6.5 mm. Suitable cable is e.g. SYKFY  $2x2x0.5~mm^2$ , where one wire pair serves for device powering and the other pair for communication link. For devices T3419L, T7311L and T7411L use cable with respect to female connector parameters. Do NOT connect shielding at connector side.

The cable should be led in one line, i.e. NOT to "tree" or "star". Termination resistor should be located at the end. For short distance other topology is allowed. Terminate the network by a termination resistor. The value of the resistor is recommended about 120  $\Omega$ . For short distance termination resistor can be left out.


The cable should not be led in parallel along power cabling. Safety distance is up to 0.5 m, otherwise undesirable induction of interference signals can appear.

Electrical system (wiring) may do only worker with required qualification by rules in operation.


## Setting of pressure correction for altitude

For devices T7311 and T7411 only! If there is necessary to read value of atmospheric pressure corrected with respect to altitude, it is possible to set corresponding pressure offset for this altitude. It is possible to do it with Users software. This value is then automatically added to measured pressure value. The resultant value of pressure with added correction for altitude must be between 300 hPa and 1350 hPa (from 4.351 PSI to 19.580 PSI). Outside this range device sends value of Error 2!


## **Dimensions - T7311**



# **Dimensions - T3419, T7411**




# **Dimensions - T7311L, T3419L, T7411L**




## Typical application wiring, connection of terminals

T7311 power from communication port

**T7311** – power from external voltage source





T3419, T7411 – RS485

Power 9+30V

RS485

#### Info mode

If in doubt of setting of installed device, verification of its address is enabled even without using computer. Power should be connected. Devices with RS232 interface have address always set to one.

Unscrew device cover and shortly press button next to connection terminals (jumper should be opened). Actual adjusted address of the device is displayed on LCD display at decimal base, for HWg-Poseidon's communication protocol there is shown number corresponding with ASCII address code. Next press of button exits info mode and actual measured values are displayed.

Note: No measurement and communication is possible during info mode. If device stays in info mode for longer than 15 s, device automatically returns to measuring cycle.

## **Description of communication protocols**

Detailed description of each communication protocols including examples of communication is available in individual document "Description of communication protocols of Txxxx series" which is free to download at <a href="https://www.cometsystem.cz">www.cometsystem.cz</a>.

Note: After switching ON the power of the device it can last up to 2 s before the device starts to communicate and measure!

#### **Modbus RTU**

Control units communicate on master-slave principle in half-duplex operation. Only master can send request and only addressed device responds. During sending of request no other slave station should respond. During communication, data transfer proceeds in binary format. Each Byte is sent as eight bit data word in format: 1 start bit, data word 8 bit (LSB first), 2 stop bits<sup>1</sup>, without parity. Device supports communication speed from 110Bd to 115200Bd.

Sent request and response have syntax: ADDRESS OF DEVICE – FUNCTION – Modbus CRC

#### **Supported functions**

**03** (**0x03**): Reading of 16-bit registers (Read Holding Registers)

**04** (**0x04**): Reading of 16-bit input gates (Read Input Registers)

**16** (**0x10**): Setting of more 16-bit registers (Write Multiple Registers)

#### Jumper and button

Jumper and button are located next to connection terminals. If communication protocol Modbus is selected the function of jumper and button is as follows:

- Jumper opened device memory is protected from writing, from the device side it is only enabled to read measured value, writing to memory is disabled (no change of device address, communication speed and LCD setting is enabled).
- Jumper closed writing to device memory is enabled by means of User's software.
- Jumper opened and button shortly pressed device goes to Info mode, see chapter "Info mode".
- Jumper closed and button pressed for longer than six seconds causes restoring of manufacturer setting **of communication protocol**, i.e. sets Modbus RTU communication protocol, device address sets to 01h and communication speed to 9600Bd after button press there is "dEF" message blinking at LCD display. Six seconds later message "dEF" stays shown, it means manufacturer setting **of communication protocol** is done.

<sup>&</sup>lt;sup>1</sup> Device sends two stop bits, for receive one stop bit is enough.

#### Modbus registers of the device

Variable	Unit	Address[hex]X	Address[dec]X	Format	Size	Status
Measured	[°C]	0x0031	49	Int*10	BIN16	R
temperature	[°F]*	0x0031	49	IIIt 10	DINIO	K
Measured relative	[%]	0x0032	50	Int*10	BIN16	R
humidity	[70]	0x0032	30	IIIt*10	DIMIO	K
Computed value *	[*]	0x0033	51	Int*10	BIN16	R
Address of device	[-]	0x2001	8193	Int	BIN16	R/W*
Code of						
communication	[-]	0x2002	8194	Int	BIN16	R/W*
speed						
Serial number of	гэ	0x1035	4150	BCD	BIN16	R
device Hi	[-]	0.1055	4130	ВСД	DIMIO	K
Serial number of	гэ	01026	1151	DCD	BIN16	R
device Lo	[-]	0x1036	4151	BCD	DIMIO	K
Version of	гэ	0x3001	12289	BCD	BIN16	R
Firmware Hi	[-]	0x3001	12209	ВСД	DIMIO	K
Version of	гэ	0x3002	12290	BCD	BIN16	R
Firmware Lo	[-]	UX3002	12290	BCD	DIMIO	K

Addition for devices T7311 and T7411 - with atmospheric pressure measurement

Variable	Unit*	Address[hex]X	Address[dec]X	Format	Size	Status
	hPa			Int*10		
	PSI	1		Int*1000		
	inHg			Int*100		
Atmospheric	mBar	0x0034	52	Int*10	BIN16	R
pressure	oz/in <sup>2</sup>	0x0034	32	Int*10	BINTO	K
	mmHg			Int*10		
	inH <sub>2</sub> O			Int*10		
	kPa			Int*100		

#### **Explanation:**

- \* depends on device setting (by User's software)
- Int\*10 register is in format integer\*10
- R register is designed only for reading
- W\* register is designed for writing, for details see file "Description of communication protocols of Txxxx series"
- register addresses are indexed from zero register 0x31 is physically sent as value 0x30, 0x32 as 0x31 (zero based addressing).

**Note:** In case there is a need for reading of measured values from the device with higher resolution than one decimal, measured values in device are stored also in "Float" format, which is not directly compatible with IEEE754.

## Protocol compatible with Advantech-ADAM standard

Control units communicate on master-slave principle in half-duplex operation. Only master can send requests and only addressed device responds. During sending request any of slave devices should respond. During communication data is transferred in ASCII format (in characters). Each Byte is sent as two ASCII characters. Device supports communication speed from 1200Bd to 115200Bd, parameters of communication link are 1 start bit + eight bit data word (LSB first) + 1 stop bit, without parity.

#### **Jumper**

Jumper is located next to connection terminals. If communication protocol compatible with standard Advantech-ADAM is selected, its function is the following:

- If jumper during switching ON the power is closed, device always communicates with following parameters regardless stored setting in the device: communication speed 9600 Bd, without check sum, device address 00h
- If jumper during switching ON the power is not closed, device communicates in accordance with stored setting.
- If jumper is closed during device operation, device temporarily changes its address to 00h, it will communicate in the same communication speed as before closing jumper and will communicate without check sum. After jumper is opened setting of address and check sum is reset in accordance with values stored in the device.
- Communication speed and check sum are possible to change only if jumper is closed.
- Jumper closed and button pressed for longer than six seconds causes restoring of manufacturer setting **of communication protocol**, i.e. sets Modbus RTU communication protocol, device address sets to 01h and communication speed to 9600Bd after button press there is "dEF" message blinking at LCD display. Six seconds later message "dEF" stays shown, it means manufacturer setting **of communication protocol** is done.

For communication with device which measure more than one value, there is necessary to add at the end of command, number of communication channel, where the measured value is mapped. Command for value reading is #AAx(CRC) CR, where AA is device address and x is number of communication channel by next table:

Measured value	Number of communication				
	channel				
Temperature	0				
Relative humidity	1				
Computed value	2				
Atmospheric	2				
pressure	3				

## **ARION** communication protocol - **AMiT** company

The device supports communication protocol ARiON version 1.00. For more details see file "Description of communication protocols of Txxxx series" or <a href="www.amit.cz">www.amit.cz</a>.

## **Communication with HWg Poseidon units**

Device supports communication with HWg-Poseidon units. For communication with this unit set the device with setup software TSensor to communication protocol HWg-Poseidon and set correct device address. This communication protocol supports read temperature at °C, relative humidity, one of computed value (dew point temperature or absolute humidity) and barometric pressure at kPa (depended by device type). For atmospheric pressure correction to altitude setting there is Users software Tsensor.

#### Jumper and button

If communication with HWg Poseidon unit is selected, the function of jumper and button is as follows:

• Jumper opened and button shortly pressed – device goes to Info mode, see chapter "Info mode".

• Jumper closed and button pressed for longer than six seconds – causes restoring of manufacturer setting **of communication protocol**, i.e. sets Modbus RTU communication protocol, device address sets to 01h and communication speed to 9600Bd - after button press there is "dEF" message blinking at LCD display. Six seconds later message "dEF" stays shown, it means manufacturer setting **of communication protocol** is done.

#### **Error States of the device**

Device continuously checks its state during operation. In case error is found LCD displays corresponding error code:

#### Error 0

First line displays "Err0".

Check sum error of stored setting inside device's memory. This error appears if incorrect writing procedure to device's memory occurred or if damage of calibration data appeared. At this state device does not measure and calculate values. It is a serious error, contact distributor of the device to fix.

#### Error 1

Measured or calculated value except in pressure is over upper limit of allowed full scale range. There is a reading "Err1" on LCD display. Value read from the device is +999.9. (for pressure reading there is +999.9 hPa correct value).

This state appears in case of:

- Measured temperature is higher than approximately 600°C (i.e. high non-measurable resistance of temperature sensor, probably opened circuit).
- Relative humidity is higher than 100%, i.e. damaged humidity sensor, or humidity calculation of humidity is not possible (due to error during temperature measurement).
- Computed value calculation of the value is not possible (error during measurement of temperature or relative humidity or value is over range).

#### Error 2

There is a reading "Err2" on LCD display. Measured or calculated value is below lower limit of allowed full scale range. Value read from the device is -999.9.

This state appears in case of:

- Measured temperature is lower than approximately -210°C (i.e. low resistance of temperature sensor, probably short circuit).
- Relative humidity is lower than 0%, i.e. damaged sensor for measurement of relative humidity, or calculation of humidity is not possible (due to error during temperature measurement).
- Measured pressure value with added correction for altitude is outside of range from 300 hPa to 1350 hPa (from 4.351 PSI to 19.580 PSI) or the pressure sensor is damaged. Please check setting of pressure correction for altitude with User's software.
- Computed value calculation of computed value is not possible (error during measurement of temperature or relative humidity).

#### Error 3

There is a reading "Err3" on LCD display upper line.

Error of internal A/D converter appeared (converter does not respond, probably damage of A/D converter). This error does NOT affect pressure measurement. Rest values are NOT measured. It is a serious error, contact distributor of the device.

#### Error 4

There is a reading "Err4" on LCD display. It is internal device error during pressure sensor initialization. Under this condition device does NOT measure atmospheric pressure. Value read from device is -999.9. Pressure sensor is probably damaged. It is a serious error, contact distributor of the device.

## Readings on LCD display

°C, °F

Reading next to this symbol is measured temperature or error state of value.

#### %RH

Reading next to this symbol is measured relative humidity or error state of value.

#### hPa, PSI, inHg,

Reading next to this symbol is measured pressure or error state of value. If selected pressure unit is mBar or  $oz/in^2$  or mmHg or  $inH_2O$  or kPa, there is shown only value (number) without corresponding pressure unit!

#### °C/°F DP

Reading next to this symbol is calculated dew point temperature or error state of value.

## $g/m^3$

Reading next to this symbol is calculated absolute humidity or error state of value.

#### g/kg

Reading next to this symbol is calculated specific humidity or mixing ratio (depends on device setting) or error state of value.

If specific enthalpy is selected, there is shown only value (number) without corresponding unit!

symbol 3 near by left display margin Is on if jumper is closed.

## **Technical parameters of the device:**

#### RS 485 Interface:

Receiver-Input Resistance:  $96 \text{ k}\Omega$ 

Devices on bus: max. 256 (1/8 Unit Receiver Load)

### Measuring parameters:

#### **Ambient temperature** (RTD sensor Pt1000/3850ppm):

Measuring range:  $-30 \text{ to } +105 \text{ }^{\circ}\text{C}$ 

Display resolution:  $0.1 \,^{\circ}\text{C}$ Accuracy:  $\pm 0.4 \,^{\circ}\text{C}$ 


#### **Relative humidity** (reading is temperature compensated at entire temperature range):

Measuring range: 0 to 100 %RH (see Device installation)

Display resolution: 0.1 %RH

Accuracy:  $\pm 2.5 \%$ RH from 5 to 95 %RH at 23 °C

# Measuring temperature and humidity range is limited in accordance with the graph below!



#### Atmospheric pressure (T7311, T7411 only):

Unit	hPa, mBar	PSI	mmHg	inHg	inH <sub>2</sub> O	oz/in <sup>2</sup>	kPa
Range	600	8.70	450.0	17.72	240.9	139.2	60.00
	1100	15.95	825.1	32.48	441.6	255.3	110.00
accuracy							
T=23 °C	±1.3	±0.02	±1.0	±0.04	±0.5	±0.3	±0.13
0≤T≤40°C	±1.5	±0.02	±1.1	±0.04	±0.6	±0.3	±0.15
Else	±2.0	±0.03	±1.5	±0.06	±0.8	±0.5	±0.20

#### The value computed from air temperature and relative humidity:

Display resolution: 0.1 °C

You can choice one of the next value:

#### Dew point temperature

Accuracy:  $\pm 1.5$  °C at air temperature T < 25°C and RH > 30%

Range:  $-60 \text{ to } +80 \text{ }^{\circ}\text{C}$ 

**Absolute humidity** 

Accuracy:  $\pm 3g/m^3$  at air temperature T <  $40^{\circ}$ C

Range:  $0 \text{ to } 400 \text{ g/m}^3$ 

Specific humidity<sup>2</sup>

Accuracy:  $\pm 2g/kg$  at air temperature T < 35°C

Range: 0 to 550 g/kg

Mixing ratio<sup>2</sup>

Accuracy:  $\pm 2g/kg$  at air temperature T < 35°C

Range: 0 to 995 g/kg

Specific enthalpy<sup>2</sup>

Accuracy:  $\pm 3kJ/kg$  at air temperature T < 25°C

Range:  $0 \text{ to } 995 \text{ kJ/kg}^{-3}$ 

**Response time** with stainless steel mesh sensor cover (F5200B) and bronze sensor cover (F0000 - selectable option), air flow approximately 1 m/s:

temperature: t90 < 9 min (temperature step 20 °C)

relative humidity: t90 < 30 s (humidity step 65 %RH, constant temperature)

atmospheric pressure<sup>4</sup>: t90 <44s

**Recommended calibration interval:** 1 year

**Measuring interval and LCD display refresh:** 0.5 s, atmospheric pressure 2 s

Power: 9 to 30 V dc

**Consumption T7311** (**RS232**) 6mA

**T3419, T7411 (RS485)** max 0.5 W

Protection of the case with electronics and terminals: T3419 IP65

T7311, T7411 IP54

Protection of the sensor cover: IP40

Filtering ability of the sensor cover: 0.025 mm

**Operating conditions:** 

Operating temperature range of case with electronics: -30 to +80 °C, over +70°C switch LCD display OFF

Operating temperature range of measuring tip with sensors and cable: -30 to +105°C.

Operating relative humidity range: 0 to 100 %RH

Outer influence in accordance with Czech National Standard 33-2000-3:

normal environment with those specifications: AE1, AN1, AR1, BE1

Working position: negligible (see device installation)

Electromagnetic compatibility: complies EN 61326-1

**Not allowed manipulation:** It is not allowed to operate the device under conditions other than specified in technical parameters. Devices are not designed for locations with chemically aggressive environment. Temperature and humidity sensors must not be exposed to direct contact with water or other liquids. It is not allowed to remove the sensor cover to avoid any mechanical damage of the sensors.

Do not use the device in an explosive environment.

Storing conditions: temperature -30 to +80 °C, humidity 0 to 100 %RH without condensation

**Dimensions:** see dimensional drawings

<sup>&</sup>lt;sup>2</sup> This value depends on the barometric pressure. If device doesn't support pressure measurement, then constant value stored inside device memory is used. Default value preset by manufacturer is 1013hPa and can be changed by user's software.

<sup>&</sup>lt;sup>3</sup> This maximum is reached under conditions about 70°C/100%RH or 80°C/70%RH

<sup>&</sup>lt;sup>4</sup> There is possible to change response time. For more details see file "Description of calibration and adjustment procedure.pdf", which is installed together with Users software.

#### Weight approximately:

T7311/1m probe cca 290 g, T7311/2m probe cca 330 g, T7311/4m probe cca 410g T7311L/1m probe, T7411(L)/1m probe, T3419(L)/1m probe cca 210g T7311L/2m probe, T7411(L)/2m probe, T3419(L)/2m probe cca 250 g

T7311L/4m probe, T7411(L)/4m probe, T3419(L)/4m probe cca 330 g

Material of the case: ABS

## **End of operation**


Device itself (after its life) is necessary to liquidate ecologically!

## **Technical support and service**

Technical support and service is provided by distributor. For contact see warranty certificate.

## **Appendix A**

#### Connection of ELO E06D (RS232/RS485) and ELO 214 (USB/RS485) converters



The ELO E06D converter is an optional accessory for connection of transmitter with RS485 interface to the PC via serial port RS232. Connect connector marked RS232 directly to the PC, connect power to connector marked RS485. Power voltage +6V DC from an external acdc adapter connect to pin 9, 0V connect to pin 5. Also mutually connect pin 2 and pin 7. Link RS485 is connected across pin 3 (A+) and pin 4 (B-).

The ELO 214 converter is an optional accessory for connection of transmitter with RS485 interface to the PC via USB port. Link RS485 is connected across **pin 9 (A+)** and **pin 8 (B-)**.

Appendix B		T		Г	
Appendix B	Female Lumberg connector	Transmitter Tx1xxL	Transmitter Tx2xxL	Transmitter Tx3xxL	Transmitter Tx4xxL
		with 4-20mA outputs	with 0-10V outputs	with RS232 output	with RS485 output
	1	+11	Udd	RTS	+U
	2	+12	Uout1	Rx	Α
	3	-12	Uout2	Tx	В
	4	-11	GND	GND	GND